

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACF418		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SAUER, JOHN						Phone # (920)810-3316		1. Well Location				Fire # (if avail.)			
Mailing Address N4483 DPRPTHY JANE CT						Town of MIDDLE INLET						W6199			
City FREEDOM						State WI		Zip Code 54130				Street Address or Road Name and Number			
SAND HILL LN						Subdivision Name				Lot #		Block #			
County Marinette		Co. Permit #		Notification # 9653418301		Completed 07-02-2025		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Well Constructor (Business Name) LUISIER WELL DRILLING INC						Lic. # 157		Facility ID # (Public Wells)				45.2645 °N -87.9076 °W		SCR002	
Address 220 HANK MARKS DR OCONTO FALLS WI 54154-1078						Well Plan Approval #		NW NE		Section 8		Township 32 N		Range 21 E	
								or Govt Lot #		8		32 N		21 E	
Approval Date (mm-dd-yyyy)						2. Well Type New Well									
Hicap Permanent Well #						Common Well #		Specific Capacity 0		of previous unique well #				constructed in	
Reason for replaced or reconstructed well ?						Construction Type Drilled									
3. Well serves 1 # of HOME						Hicap Well ? No		Private, potable				Hicap Property ? No			
Heat Exchange ___ # of drillholes						Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8.75 Surface 156			Yes Rotary - Mud Circulation No												
6 156 196			No Rotary - Air No												
			No Rotary - Air & Foam Yes												
			No Drill-Through Casing Hammer												
			No Reverse Rotary												
			No Cable-tool Bit ___ in. dia... No												
			No Dual Rotary No												
			No Temp. Outer Casing ___ in. dia												
			No Removed? ___ depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...							From (ft.)		To (ft.)			
C			C-CLAY							Surface		63			
Z			Z-CLAY & GRAVEL							63		77			
G			G-GRAVEL/STONES							77		91			
D N			D-DECOMPOSED/WEATHERED N-SANDSTONE							91		114			
N			N-SANDSTONE							114		196			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW P.E. 18.97 WHEATLAND A-53				Surface		156							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT GROUT				Surface		156		30 S							
9. Static Water Level															
5 ft. below ground surface															
10. Pump Test															
Pumping level 160 ft. below surface															
Pumping at 30 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
KM				5864		07-02-2025									
Drill Rig Operator				Lic or Reg #		Date Signed									
MP				8833		07-02-2025									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: NO SEPTIC AT THE TIME OF DRILLING. WE WILL BE INSTALLING THE WATER SYSTEM.

Created On: 07-03-2025

Updated On: 08-25-2025

Review Status: APPROVED