

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACF419		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner NIEDERMEYER, ROB				Phone # (920)321-8564		1. Well Location				Fire # (if avail.)	
Mailing Address 2821 E MILESTONE CT						Town of FLORENCE					
City APPLETON				State WI		Zip Code 54913					
County Florence		Co. Permit #		Notification # 9762221901		Completed 07-02-2025		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) LUISIER WELL DRILLING INC				Lic. # 157		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.91787 °N -88.37481 °W		Method Code SCR002	
Address 220 HANK MARKS DR OCONTO FALLS WI 54154-1078				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 28 40 N 17 E					
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) 8.75		From (ft.) Surface		To (ft.) 29		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
						Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Y C Type, Caving/Noncaving, Color, Hardness, etc... Y-SAND & GRAVEL C-CLAY From (ft.) Surface 29 To (ft.) 29	
6. Casing, Liner, Screen											
Dia. (in.) 5		Material, Weight, Specification Manufacturer & Method of Assembly CRESLINE PVC-1120 SCH 40 200 PSI-F480				From (ft.) Surface		To (ft.) 25		9. Static Water Level 11 ft. below ground surface	
Dia. (in.) 5		Screen type, material & slot size 15 SLOT S.S. SCREEN				From (ft.) 25		To (ft.) 29		10. Pump Test Pumping level 20 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ? Airlift	
7. Grout or Other Sealing Material											
Method TREMIE PIPE - PUMPED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
QUIK GROUT		Surface		25		3 S					
#40 GRAVEL PACK (RED FLINT SAND & GRAVEL LLC)		25		29		6 S					
12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller KM				Lic # 5864		Date Signed 07-02-2025					
Drill Rig Operator MP				Lic or Reg # 9084		Date Signed 07-02-2025					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: NO SEPTIC AT THE TIME OF DRILLING. WE WILL BE INSTALLING THE WATER SYSTEM.
PARCEL #010-01399-0000

Created On: 07-03-2025

Updated On: 08-25-2025

Review Status: APPROVED