

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACF511		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WEGAND, MARK & JENNIFER				Phone # (920)915-4257		1. Well Location				Fire # (if avail.)					
Mailing Address W2266 OUT OF TOWN LN						Town of TIPLER									
City KAUKAUNA				State WI		Zip Code 54130									
County Florence		Co. Permit #		Notification # 9830884401		Completed 07-07-2025		Subdivision Name				Lot # 3		Block #	
Well Constructor (Business Name) LUISIER WELL DRILLING INC				Lic. # 157		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.92319 °N -88.59415 °W				Method Code SCR002	
Address 220 HANK MARKS DR OCONTO FALLS WI 54154-1078				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 27 40 N 15 E									
Approval Date (mm-dd-yyyy)						2. Well Type New Well				of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ?									
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No		Heat Exchange ___ # of drillholes		Hicap Potable ? No	
						Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 8.75		From (ft.) Surface		To (ft.) 122		Upper Enlarged Drillhole				Lower Open Bedrock					
						Yes Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
Z		Z-CLAY & GRAVEL				Surface		90							
X		X-SAND & CLAY				90		100							
Y		Y-SAND & GRAVEL				100		122							
6. Casing, Liner, Screen															
Dia. (in.) 5		Material, Weight, Specification Manufacturer & Method of Assembly NASP PVC-1120 SCH 40 200 PSI F-480				From (ft.) Surface		To (ft.) 118							
Dia. (in.) 5		Screen type, material & slot size 15 S.S SLOT SCREEN				From (ft.) 118		To (ft.) 122							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
QUIK GROUT		Surface		118		18 S									
#40 GRAVEL PACK (RED FLINT SAND & GRAVEL LLC)		118		122		6 S									
9. Static Water Level															
102 ft. below ground surface															
10. Pump Test															
Pumping level 110 ft. below surface															
Pumping at 4 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
KM				5864		07-08-2025									
Drill Rig Operator				Lic or Reg #		Date Signed									
MP				9084		07-08-2025									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: NO SEPTIC AT THE TIME OF DRILLING. WE WILL BE INSTALLING THE WATER SYSTEM.

Created On: 07-08-2025

Updated On: 08-25-2025

Review Status: APPROVED