

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACF514		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner TILLY, PAT				Phone # (920)265-2043		1. Well Location				Fire # (if avail.)		
Mailing Address 3138 MEADOW HEIGHTS CT						Town of MIDDLE INLET				7460		
City SUAMICO				State WI Zip Code 54313		Street Address or Road Name and Number CREEK RD						
County Marinette		Co. Permit #		Notification # 9938800401		Completed 07-07-2025		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) LUISIER WELL DRILLING INC				Lic. # 157		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.3097 °N -87.97 °W			Method Code SCR002	
Address 220 HANK MARKS DR OCONTO FALLS WI 54154-1078				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 23 33 N 20 E		2. Well Type New Well				
Hicap Permanent Well #				Common Well #		Specific Capacity 0		of previous unique well # constructed in				
3. Well serves 1 # of CABIN				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?				
Private, potable				Hicap Potable ? No		Construction Type Drilled						
Heat Exchange ___ # of drillholes												
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.) 8.75		From (ft.) Surface		To (ft.) 103		Upper Enlarged Drillhole			Lower Open Bedrock			
						Yes Rotary - Mud Circulation			No			
						No Rotary - Air			No			
						No Rotary - Air & Foam			No			
						No Drill-Through Casing Hammer						
						No Reverse Rotary						
						No Cable-tool Bit ___ in. dia...			No			
						No Dual Rotary			No			
						No Temp. Outer Casing ___ in. dia						
						No Removed? ___ depth ft. (If NO explain on back side)						
8. Geology												
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)			
Y			Y-SAND & GRAVEL			Surface			85			
X G			X-SAND & CLAY G-W/GRAVEL/STONES			85			103			
6. Casing, Liner, Screen												
Dia. (in.) 5		Material, Weight, Specification Manufacturer & Method of Assembly CRESLINE PVC-1120 SCH 40 200 PSI -F-480				From (ft.) Surface		To (ft.) 95				
Dia. (in.) 5		Screen type, material & slot size (2) 12 SLOT S.S. SCREEN				From (ft.) 95		To (ft.) 103				
7. Grout or Other Sealing Material												
Method TREMIE PIPE - PUMPED												
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement						
QUIK GROUT		Surface		95		10 S						
#40 GRAVEL PACK (RED FLINT SAND & GRAVEL LLC)		95		103		16 S						
9. Static Water Level												
50 ft. below ground surface												
10. Pump Test												
Pumping level 90 ft. below surface												
Pumping at 3 GP M for 6 Hrs.												
Pumping Method ? Airlift												
11. Well Is												
24 in. above grade												
Developed ? Yes												
Disinfected ? Yes												
Capped ? Yes												
12. Notified Owner of need to fill & seal ? No												
Filled & Sealed Well(s) as needed? No												
13. Constructor / Supervisory Driller												
KM		Lic # 5864		Date Signed 07-08-2025								
Drill Rig Operator		Lic or Reg # 8833		Date Signed 07-08-2025								
ZJ												

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: NO SEPTIC AT THE TIME OF DRILLING. WE WILL BE INSTALLING THE WATER SYSTEM.

Created On: 07-08-2025

Updated On: 08-25-2025

Review Status: APPROVED