Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACF751

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RYAN CLEMENTS	Phone #
Mailing Address: W2298 STATE RD 33	
City: LA CROSSE	State: WI / Zip Code: 54601
County: La Crosse	Co. Permit #: 2024062 / Notification #: 9903011601 / Completed: 07-11-2025
Well Constructor (Business Name): HOLLER, WAYNE	Lic. #: 4668 / Facility ID # (Public Wells)
Address: HOLLER PLUMBING & WELL DRILLING N2995 SMITH VALLEY RD LA CROSSE WI 54601-2935	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # / Specific Capacity: 0.1

1. Well Location

Town of WASHINGTON	Fire # (if avail.): N2024
Street Address or Road Name and Number: BINA RD	
Subdivision Name	Lot # / Block #
Latitude / Longitude in Decimal Degree (DD): 43.79686 °N -91.00736 °W	Method Code: GPS008
NW NW or Govt Lot #	Section: 8 / Township: 15 N / Range: 5 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	237
6	237	400

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 14depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	H	C	C	R-RED H-HARD/FIRM C-CLAY C-CLAYEY	Surface	12
Y	F	L	C	Y-YELLOW F-FRACTURED L-LIMESTONE/DOLOMITE C-CLAYEY	12	60
I	H	L	L	I-WHITE H-HARD/FIRM L-LIMESTONE/DOLOMITE L-LIMEY OR DOLOMITIC	60	135
Y	H	H	H	Y-YELLOW H-HARD/FIRM H-SHALE H-SHALEY	135	175
Y	S	N	N	Y-YELLOW S-SOFT/LOOSE N-SANDSTONE N-W/SANDSTONE	175	200
Y	H	N	N	Y-YELLOW H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE	200	380
G	H	H	N	G-GRAY H-HARD/FIRM H-SHALE N-W/SANDSTONE	380	400

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM-A53.280 WALL WHEATLAND USA MADE PLAIN END WELD	Surface	237
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	237	92 S

9. Static Water Level	11. Well Is	
260 ft. below ground surface	26 in. above grade	
10. Pump Test	Developed ?	Yes
Pumping level 380 ft. below surface	Disinfected ?	Yes
Pumping at 12 GP M for 6 Hrs.	Capped ?	Yes
Pumping Method ? Test Pump		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WH	4668	07-19-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		85	Building Drain - Sanitary		56
POWTS dispersal component (soil absorption unit or mound)		110	Landfill	>	1200
			Sewer - Building Sanitary		68

Comment:

Created On: 07-14-2025 Updated On: 10-15-2026 Review Status: APPROVED