

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACF751		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner RYAN CLEMENTS						Phone #									
Mailing Address W2298 STATE RD 33						Town of WASHINGTON						Fire # (if avail.) N2024			
City LA CROSSE				State WI		Zip Code 54601									
County La Crosse		Co. Permit # 2024062		Notification # 9903011601		Completed 07-11-2025		Street Address or Road Name and Number BINA RD							
Well Constructor (Business Name) HOLLER, WAYNE						Lic. # 4668		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.79686 °N -91.00736 °W		Method Code GPS008	
Address HOLLER PLUMBING & WELL DRILLING N2995 SMITH VALLEY RD LA CROSSE WI 54601-2935						Well Plan Approval #				NW NW Section Township Range or Govt Lot # 8 15 N 5 W		2. Well Type New Well			
Hicap Permanent Well #						Common Well #		Specific Capacity 0				Reason for replaced or reconstructed well ?			
3. Well serves 1 # of HOME						Hicap Well ? No				Private, potable Drillhole		Hicap Property ? No			
Heat Exchange ___ # of drillholes						Hicap Potable ? No				Construction Type Drilled		Approval Date (mm-dd-yyyy)			
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 237			No Rotary - Mud Circulation No												
6 237 400			No Rotary - Air No												
			Yes Rotary - Air & Foam Yes												
			No Drill-Through Casing Hammer												
			No Reverse Rotary												
			No Cable-tool Bit ___ in. dia... No												
			No Dual Rotary No												
			Yes Temp. Outer Casing 10in. dia												
			Yes Removed? 14depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.) To (ft.)							
R H C C				R-RED H-HARD/FIRM C-CLAY C-CLAYEY				Surface 12							
Y F L C				Y-YELLOW F-FRACTURED L-LIMESTONE/DOLOMITE C-CLAYEY				12 60							
I H L L				I-WHITE H-HARD/FIRM L-LIMESTONE/DOLOMITE L-LIMEY OR DOLOMITIC				60 135							
Y H H H				Y-YELLOW H-HARD/FIRM H-SHALE H-SHALEY				135 175							
Y S N N				Y-YELLOW S-SOFT/LOOSE N-SANDSTONE N-W/SANDSTONE				175 200							
Y H N N				Y-YELLOW H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE				200 380							
G H H N				G-GRAY H-HARD/FIRM H-SHALE N-W/SANDSTONE				380 400							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)									
6		ASTM-A53.280 WALL WHEATLAND USA MADE PLAIN END WELD				Surface 237									
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)									
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.) To (ft.)		# Sacks Cement									
NEAT CEMENT GROUT				Surface 237		92 S									

9. Static Water Level

260 ft. below ground surface

10. Pump Test

Pumping level 380 ft. below surface

Pumping at 12 GP M for 6 Hrs.

Pumping Method ? Test Pump

11. Well Is

26 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

WH

4668

07-19-2025

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		85	Building Drain - Sanitary		56
POWTS dispersal component (soil absorption unit or mound)		110	Landfill	>	1200
			Sewer - Building Sanitary		68

Comment:

Created On: 07-14-2025

Updated On: 08-25-2025

Review Status: APPROVED