

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACG339		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner LOCKSTEIN ERIC					Phone #		1. Well Location Fire # (if avail.) Town of BLOOMFIELD W631 Street Address or Road Name and Number COUNTY ROAD H					
Mailing Address W631 COUNTY ROAD H												
City FREMONT			State WI		Zip Code 54940		Subdivision Name Lot # Block #					
County Waushara		Co. Permit # Wisconsin		Notification # 9929369501		Completed 07-16-2025						
Well Constructor (Business Name)			Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
LOEHRKE, NEAL D			133				44.15718 °N -88.91125 °W				SCR002	
Address VALLEY WELL DRILLING N1600 HWY 10 S WEYAUWEGA WI 54983			Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW SE Section Township Range					
							or Govt Lot # 35 20 N 13 E					
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? QUPDATE BURIED SUCTION PUMP TO SUBMERSIBLE Construction Type Drilled						
				4								
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...			
6	Surface	179	No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						C C-CLAY Surface 140 X X-SAND & CLAY 140 163 N N-SANDSTONE 163 179			
6. Casing, Liner, Screen												
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)	9. Static Water Level 3 ft. above ground surface 10. Pump Test Pumping level 6 ft. below surface Pumping at 12 GP M for 30 Hrs. Pumping Method ? Test Pump						
6	STEEL 18.97 LBS/FT A53 GR B NUCOR WELDED			Surface	163							
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)	11. Well Is 50 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes						
7. Grout or Other Sealing Material												
Method MOUNDED												
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement								
GRANULAR BENTONITE		Surface		2 S								
12. Notified Owner of need to fill & seal ? Yes 137.5 = 4" FLOWING WELL Filled & Sealed Well(s) as needed? Yes VWD FILLED & SEALED 8/7/2025												
13. Constructor / Supervisory Driller						Lic #		Date Signed				
NL						133		07-16-2025				
Drill Rig Operator						Lic or Reg #		Date Signed				
NL						133		07-16-2025				

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 07-30-2025

Updated On: 12-23-2025

Review Status: APPROVED