Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACG862

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RICHARD ELLER	Phone #: (715)866-7235
Mailing Address: 28695 PALMBORG EXTENSION	
City: DANBURY, WI	State: WI Zip Code: 54830
County: Burnett	Co. Permit #: Wisconsin
Notification #: 9972262201	Completed: 08-13-2025
Well Constructor (Business Name): ARNOLD, WILLIAM JR	Lic. #: 4514
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: BILL ARNOLD PUMP & WELL 28290 STATE RD 35 DANBURY WI 54830	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity	

1. Well Location

Town of UNION	Fire # (if avail.): 28695
Street Address or Road Name and Number: 28695 PALMBORG EXTENSION	
Subdivision Name	Lot # / Block #
Latitude / Longitude in Decimal Degree (DD): 45.95664 °N -92.41847 °W	Method Code: GPS008
NE NW or Govt Lot #	Section: 13 Township: 40 N Range: 17 W

2. Well Type Replacement

of previous unique well # constructed in 1975

Reason for replaced or reconstructed well ?

PUMPING SAND

Construction Type: Driven Point

3. Well serves 1 # of CABIN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
1.25	Surface	29

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Q S	T-TAN/BROWN Q-CAVING S-SAND	Surface	29

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
1.25	GALV. STEEL SCH 40 ASTM A53 THREADED AND COUPLED	Surface	25
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	SIMMONS 1724-1 60GA STAINLESS	25	29

9. Static Water Level

4 ft. below ground surface

10. Pump Test

Pumping level 4 ft. below surface

Pumping at 42 GP M for _____ Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
WA	4514	08-13-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		48	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 08-13-2025 Updated On: 09-03-2025 Review Status: APPROVED