Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACH427

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ERNST RICH			Phone #
Mailing Address: 1192A HENRY LANE			
City: FOUNTAIN CITY	State: WI	Zip Code: 54629	
County: Buffalo	Co. Permit #:	Notification #: 9945373501	Completed: 08-06-2025

Well Constructor (Business Name): HARTERT, EDWARD A	Lic. #: 4424	Facility ID # (Public Wells):	
Address: HARTERT WELL DRILLING 14497 N CTY RD 24 WABASHA MN 55981		Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 15	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of MILTON			Fire # (if avail.): 1192A
Street Address or Road Name and Number: 1192A HENRY LANE			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 44.18281 °N -91.77166 °W			Method Code: SCR002
SW NW or Govt Lot #:	Section: 25	Township: 20 N	Range: 12 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	3
4	3	42

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	S	T-TAN/BROWN Q-CAVING S-SAND S-SANDY	Surface	26
G	Q	S	S	G-GRAY Q-CAVING S-SAND S-SANDY	26	42

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	STEEL,11.OOLBS' ASTMA53B. WEATLAND T-N-C	Surface	38
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	TELESCOPING SS 15SLOT	38	42

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	38	1.5 S

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 16 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
EH	4424	09-02-2025
Drill Rig Operator	Lic or Reg #	Date Signed
EH	4424	09-02-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		50
POWTS dispersal component (soil absorption unit or mound)		70

Type	Qualifier	Distance
Building Drain - Sanitary		10
Sewer - Building Sanitary		35

Comment:

Created On: 09-02-2025 Updated On: 10-15-2026 Review Status: APPROVED