Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACH428

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ADAMSON CHRIS	Phone #
Mailing Address: 9749 THUNDERBLUFF RD.NW	
City: OR0NOCO	State: MN Zip Code: 55960

County	Co. Permit #	Notification #	Completed
Buffalo		9987007801	08-01-2025

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
HARTERT, EDWARD A	4424	

Address: HARTERT WELL DRILLING 14497 N CTY RD 24
WABASHA MN 55981

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		15

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

City of BUFFALO CITY

Fire # (if avail.): 1151

Street Address or Road Name and Number: 1151 S. RIVER ROAD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.21857 °N -91.85164 °W	SCR002

SW SW or Govt Lot #	Section	Township	Range
	8	20 N	12 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	3
4	3	43

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	S	T-TAN/BROWN Q-CAVING S-SAND S-SANDY	Surface	43

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	STEEL,11.OOLBS' ASTMA53B. WEATLAND T-N-C	Surface	43
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	TELESCOPING SS 12SLOT	39	43

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	39	2 S

9. Static Water Level
16 ft. below ground surface

10. Pump Test
Pumping level 17 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
EH	4424	09-02-2025
Drill Rig Operator	Lic or Reg #	Date Signed
EH	4424	09-02-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		140
POWTS dispersal component (soil absorption unit or mound)		160

Type	Qualifier	Distance
Building Drain - Sanitary		31
Sewer - Building Sanitary		120

Comment:

Created On: 09-02-2025 Updated On: 10-15-2026 Review Status: APPROVED