

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACH428		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner ADAMSON CHRIS				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 9749 THUNDERBLUFF RD.NW				City of BUFFALO CITY		1151				Street Address or Road Name and Number	
City ORONOCO				State MN		Zip Code 55960				1151 S. RIVER ROAD	
County Buffalo		Co. Permit #		Notification # 9987007801		Completed 08-01-2025		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) HARTERT, EDWARD A				Lic. # 4424		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.21857 °N -91.85164 °W	
Address HARTERT WELL DRILLING 14497 N CTY RD 24 WABASHA MN 55981				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 8 20 N 12 W		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 0				Reason for replaced or reconstructed well ?	
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No	
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled				Method Code SCR002	
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
8		Surface		3		No Rotary - Mud Circulation		No		Geology Codes T Q S S	
4		3		43		No Rotary - Air		No		Type, Caving/Noncaving, Color, Hardness, etc... T-TAN/BROWN Q-CAVING S-SAND S-SANDY	
						No Rotary - Air & Foam		No		From (ft.) To (ft.) Surface 43	
						No Drill-Through Casing Hammer					
						No Reverse Rotary					
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is	
4		STEEL, 11.00LBS' ASTMA53B. WEATLAND T-N-C				Surface		43		18 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes	
4		TELESCOPING SS 12SLOT				39		43		Disinfected ? Yes	
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Capped ? Yes	
GRANULAR BENTONITE				Surface		39		2 S		Filled & Sealed Well(s) as needed? No	
9. Static Water Level											
16 ft. below ground surface											
10. Pump Test											
Pumping level 17 ft. below surface											
Pumping at 15 GP M for 2 Hrs.											
Pumping Method ? Test Pump											
12. Notified Owner of need to fill & seal ? No											
13. Constructor / Supervisory Driller											
EH				Lic # 4424		Date Signed 09-02-2025		No			
Drill Rig Operator				Lic or Reg #		Date Signed		No			
EH				4424		09-02-2025		No			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		140	Building Drain - Sanitary		31
POWTS dispersal component (soil absorption unit or mound)		160	Sewer - Building Sanitary		120

Comment:

Created On: 09-02-2025

Updated On: 09-03-2025

Review Status: APPROVED