

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACH724		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner KIRCHNER, PETER & JUDITH						Phone #								
Mailing Address N10251 KIRCHNER ROAD						Town of LARRABEE								
City CLINTONVILLE						State WI		Zip Code 54929						
County Waupaca		Co. Permit #		Notification # 10000322901		Completed 02-24-2026		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) SHAWANO WELL DRILLING INC				Lic. # 6001		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.6102 °N -88.7697 °W			Method Code GPS008	
Address W9618 ANGLE RD SHAWANO WI 54166				Well Plan Approval #		NE SW		Section 26		Township 25 N		Range 14 E		
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0.5						
3. Well serves 1 # of HOME						Hicap Well ? No								
Private, potable Drillhole						Hicap Property ? No								
Heat Exchange ___ # of drillholes						Hicap Potable ? No								
2. Well Type Replacement						of previous unique well # MC960 constructed in 1997								
Reason for replaced or reconstructed well ?						NITRATE CONTAMINATED WELL								
Construction Type Drilled														
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) 6		From (ft.) Surface		To (ft.) 137		Upper Enlarged Drillhole			Lower Open Bedrock					
<u>No</u>		Rotary - Mud Circulation			<u>No</u>									
<u>No</u>		Rotary - Air			<u>No</u>									
<u>No</u>		Rotary - Air & Foam			<u>No</u>									
<u>No</u>		Drill-Through Casing Hammer												
<u>No</u>		Reverse Rotary												
<u>No</u>		Cable-tool Bit ___ in. dia...			<u>No</u>									
<u>No</u>		Dual Rotary			<u>No</u>									
<u>No</u>		Temp. Outer Casing ___ in. dia												
<u>No</u>		Removed? ___ depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen														
Dia. (in.) 6		Material, Weight, Specification STEEL ASTM A53 18.97LBS/FT WHEATLAND WELDED				From (ft.) Surface		To (ft.) 133						
Dia. (in.) 6		Screen type, material & slot size STAINLESS STEEL 12 SLOT WIRE WRAP				From (ft.) 133		To (ft.) 137						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material GRANULAR BENTONITE				From (ft.) Surface		To (ft.)		# Sacks Cement 2 S						
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
R	V	C	C	R-RED V-NON-CAVING C-CLAY C-CLAYEY				Surface	27					
G	V	C	M	G-GRAY V-NON-CAVING C-CLAY M-SILTY				27	48					
R	H	C	C	R-RED H-HARD/FIRM C-CLAY C-CLAYEY				48	61					
T	A	Y	S	T-TAN/BROWN A-COARSE Y-SAND & GRAVEL S-SANDY				61	116					
T	L	S	M	T-TAN/BROWN L-FOSSILIFEROUS S-SAND M-SILTY				116	128					
T	A	S	S	T-TAN/BROWN A-COARSE S-SAND S-SANDY				128	137					

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 25 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Yes

Filled & Sealed Well(s) as needed?

Yes

13. Constructor / Supervisory Driller

Lic #

Date Signed

JDD

6331

02-24-2026

Drill Rig Operator

Lic or Reg #

Date Signed

JL

7417

02-24-2026

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		137	POWTS dispersal component (soil absorption unit or mound)		134

Comment:

ARPA-WCP-0625 NITRATE CONTAMINED WELL REPLACEMENT - APPROVAL 8/19/25 WILL ABANDON OLD WELL AT TIME OF HOOK UP IN SPRING.

Created On: 09-09-2025

Updated On: 07-01-2026

Review Status: APPROVED