Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACH724

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: KIRCHNER, PETER & JUDITH			Phone #
Mailing Address: N10251 KIRCHNER ROAD			
City: CLINTONVILLE	State: WI	Zip Code: 54929	
County: Waupaca	Co. Permit #:	Notification #: 10000322901	Completed: 02-24-2026

Well Constructor (Business Name): SHAWANO WELL DRILLING INC	Lic. #: 6001	Facility ID # (Public Wells):	
Address: W9618 ANGLE RD SHAWANO WI 54166		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

3. Well serves 1 # of HOME
Private,potable — Drillhole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of LARRABEE
Fire # (if avail.): N10251
Street Address or Road Name and Number: KIRCHNER ROAD, CLINTONVILLE, WI 54929

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.6102 °N -88.7697 °W
Method Code: GPS008

NE	SW	Section	Township	Range
or Govt Lot #		26	25 N	14 E

2. Well Type Replacement
of previous unique well # MC960 constructed in 1997
Reason for replaced or reconstructed well ?: NITRATE CONTAMINATED WELL
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	137

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	V	C	C	R-RED V-NON-CAVING C-CLAY C-CLAYEY	Surface	27
G	V	C	M	G-GRAY V-NON-CAVING C-CLAY M-SILTY	27	48
R	H	C	C	R-RED H-HARD/FIRM C-CLAY C-CLAYEY	48	61
T	A	Y	S	T-TAN/BROWN A-COARSE Y-SAND & GRAVEL S-SANDY	61	116
T	L	S	M	T-TAN/BROWN L-FOSSILIFEROUS S-SAND M-SILTY	116	128
T	A	S	S	T-TAN/BROWN A-COARSE S-SAND S-SANDY	128	137

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL ASTM A53 18.97LBS/FT WHEATLAND WELDED	Surface	133
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	STAINLESS STEEL 12 SLOT WIRE WRAP	133	137

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level	11. Well Is
8 ft. below ground surface	20 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 55 ft. below surface	Disinfected ? Yes
Pumping at 25 GP M for 2 Hrs.	Capped ? Yes
Pumping Method ? Airlift	

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JDD	6331	02-24-2026
Drill Rig Operator	Lic or Reg #	Date Signed
JL	7417	02-24-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		137	POWTS dispersal component (soil absorption unit or mound)		134

Comment: ARPA-WCP-0625 NITRATE CONTAMINED WELL REPLACEMENT - APPROVAL 8/19/25 WILL ABANDON OLD WELL AT TIME OF HOOK UP IN SPRING.

Created On: 09-09-2025 Updated On: 07-01-2026 Review Status: APPROVED