

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACI088		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner KATUIN, DAVID						Phone #													
Mailing Address N12875 CTY RD V						1. Well Location						Fire # (if avail.)							
City BOYCEVILLE						State WI		Zip Code 54725				Town of NEW HAVEN		N12875					
County Dunn						Co. Permit # 2509260		Notification # 10003579301				Completed 09-16-2025		Street Address or Road Name and Number CTY RD V					
Well Constructor (Business Name) DAHL WELL DRILLING LLC						Lic. # 6724		Facility ID # (Public Wells)				Subdivision Name		Lot #		Block #			
Address 1236 HAGAN RD GLENWOOD CITY WI 54013						Well Plan Approval #		Latitude / Longitude in Decimal Degree (DD) 45.1494 °N -92.0751 °W				Method Code GPS008							
Hicap Permanent Well #						Common Well #		Specific Capacity 4				NE NE Section Township Range or Govt Lot # 27 31 N 14 W							
3. Well serves 1 # of HOME Private, potable Drillhole Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ? No		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? IN BASEMENT Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		40		No Rotary - Mud Circulation				No		T S I		T-TAN/BROWN S-SOFT/LOOSE I-SOIL-ORGANIC		Surface		2	
6		40		80		No Rotary - Air				No		T V S C		T-TAN/BROWN V-NON-CAVING S-SAND C-CLAYEY		2		13	
						Yes Rotary - Air & Foam				Yes		T H N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE		13		26	
						No Drill-Through Casing Hammer Reverse Rotary						E H N		E-GREEN H-HARD/FIRM N-SANDSTONE		26		38	
						No Cable-tool Bit ___ in. dia...				No		T S N		T-TAN/BROWN S-SOFT/LOOSE N-SANDSTONE		38		46	
						No Dual Rotary				No		T H N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE		46		59	
						No Temp. Outer Casing ___ in. dia						G H N		G-GRAY H-HARD/FIRM N-SANDSTONE		59		64	
						No Removed? ___ depth ft. (If NO explain on back side)						T H N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE		64		70	
												I H N		I-WHITE H-HARD/FIRM N-SANDSTONE		70		80	
6. Casing, Liner, Screen																			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)											
6		MARVICH LEAVIT, STEEL, WELDED, 20#/FT, .280 WALL				Surface		46											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material																			
Method TREMIE PIPE - PUMPED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT GROUT				Surface		40		18 S											

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 29 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Yes

Filled & Sealed Well(s) as needed?

Yes

13. Constructor / Supervisory Driller

Lic #

Date Signed

AD

6830

02-26-2026

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		50	POWTS dispersal component (soil absorption unit or mound)		80

Comment:

Created On: 09-18-2025

Updated On: 03-24-2026

Review Status: APPROVED