Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACI088

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KATUIN, DAVID			Phone #
Mailing Address: N12875 CTY RD V			
City: BOYCEVILLE	State: WI	Zip Code: 54725	
County: Dunn	Co. Permit #: 2509260	Notification #: 10003579301	Completed: 09-16-2025

Well Constructor (Business Name): DAHL WELL DRILLING LLC	Lic. #: 6724	Facility ID # (Public Wells)	
Address: 1236 HAGAN RD GLENWOOD CITY WI 54013		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 4	

1. Well Location

Town of NEW HAVEN					Fire # (if avail.): N12875
Street Address or Road Name and Number: CTY RD V					
Subdivision Name			Lot #		Block #
Latitude / Longitude in Decimal Degree (DD): 45.1494 °N -92.0751 °W					Method Code: GPS008
NE	NE	Section: 27	Township: 31 N	Range: 14 W	
or Govt Lot #					

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: IN BASEMENT

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	40
6	40	80

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	MARVICHI LEAVIT, STEEL, WELDED, 20#/FT, .280 WALL	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	18 S

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	I		T-TAN/BROWN S-SOFT/LOOSE I-SOIL-ORGANIC	Surface	2
T	V	S	C	T-TAN/BROWN V-NON-CAVING S-SAND C-CLAYEY	2	13
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	13	26
E	H	N		E-GREEN H-HARD/FIRM N-SANDSTONE	26	38
T	S	N		T-TAN/BROWN S-SOFT/LOOSE N-SANDSTONE	38	46
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	46	59
G	H	N		G-GRAY H-HARD/FIRM N-SANDSTONE	59	64
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	64	70
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	70	80

9. Static Water Level	11. Well Is
26 ft. below ground surface	16 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 29 ft. below surface	Disinfected ? Yes
Pumping at 12 GP M for 1 Hrs.	Capped ? Yes
Pumping Method ? Test Pump	

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
AD	6830	02-26-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		50	POWTS dispersal component (soil absorption unit or mound)		80

Comment:

Created On: 09-18-2025 Updated On: 03-24-2026 Review Status: APPROVED