

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACI112		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner GEFFERS, JEFFREY						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N2169 COUNTY ROAD GG								Town of RICHFORD				N2169			
City HANCOCK						State WI		Zip Code 54943				Street Address or Road Name and Number COUNTY ROAD GG			
County Waushara		Co. Permit #		Notification # 10010067301		Completed 09-22-2025		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) FARAGO PLBG & TRENCHING INC				Lic. # 126		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0572 °N -89.4647 °W				Method Code GPS008	
Address 229 SHORT ST PLAINFIELD WI 54966				Well Plan Approval #		SW		SW		Section 5		Township 18 N		Range 9 E	
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type Replacement of previous unique well # constructed in					
Reason for replaced or reconstructed well ? NO LONGER WORKING															
3. Well serves 1 # of HOME Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.8		Surface		126		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ____ in. dia... No No Dual Rotary No No Temp. Outer Casing ____ in. dia No Removed? ____ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
S		S-SAND						Surface		1					
Y		Y-SAND & GRAVEL						1		25					
Z		Z-CLAY & GRAVEL						25		35					
Y		Y-SAND & GRAVEL						35		126					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level					
8.8		US NAPCO PVC NSF .480 SDR 21 SOLVENT WELD 200 PSI				Surface		121		50 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is					
5		#18 SLOT CONTINUOUS PVC				121		126		24 in. above grade					
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED										10. Pump Test Pumping level 51 ft. below surface Pumping at 30 GP M for 1 Hrs. Pumping Method ? Airlift				Developed ? Yes Disinfected ? Yes Capped ? Yes	
12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller						Lic #		Date Signed							
TF						41		09-30-2025							
Drill Rig Operator						Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		50

Comment:

Created On: 09-18-2025

Updated On: 10-17-2025

Review Status: APPROVED