Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACI112

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GEFFERS, JEFFREY	Phone #
Mailing Address: N2169 COUNTY ROAD GG	
City: HANCOCK	State: WI — Zip Code: 54943
County: Waushara	Co. Permit #: — Notification #: 10010067301 — Completed: 09-22-2025
Well Constructor (Business Name): FARAGO PLBG & TRENCHING INC	Lic. #: 126 — Facility ID # (Public Wells):
Address: 229 SHORT ST, PLAINFIELD WI 54966	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 30

1. Well Location

Town of RICHFORD	Fire # (if avail.): N2169
Street Address or Road Name and Number: COUNTY ROAD GG	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.0572 °N -89.4647 °W	Method Code: GPS008
SW SW or Govt Lot #: — Section: 5 — Township: 18 N — Range: 9 E	

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NO LONGER WORKING

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.8	Surface	126

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	S-SAND	Surface	1
Y	Y-SAND & GRAVEL	1	25
Z	Z-CLAY & GRAVEL	25	35
Y	Y-SAND & GRAVEL	35	126

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
8.8	US NAPCO PVC NSF .480 SDR 21 SOLVENT WELD 200 PSI	Surface	121
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	#18 SLOT CONTINOUS PVC	121	126

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 51 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TF	41	09-30-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		50

Comment:

Created On: 09-18-2025 Updated On: 10-15-2026 Review Status: APPROVED