Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACI207

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: KESSLER JESSIE	Phone #: (715)520-7997
Mailing Address: N7415 CORRELL RD.	
City: TREGO	State: WI — Zip Code: 54888
County: Washburn	Co. Permit #:
Notification #: 9929321701	Completed: 08-14-2025
Well Constructor (Business Name): RUTHERFORD, JEFFREY J	Lic. #: 6202
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: H20 WELL & PUMP N11455 MC CLAIN LAKE RD, TREGO WI 54888	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.3	

1. Well Location

Town of SPRINGBROOK	Fire # (if avail.): N7415
Street Address or Road Name and Number: N7415 CORRELL RD.	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9039 °N -91.7644 °W	Method Code: OTH001

NE	SE	Section	Township	Range
or Govt Lot #		31	40 N	11 W

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	72

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 3.75in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	A	Y		T-TAN/BROWN A-COARSE Y-SAND & GRAVEL	Surface	38
T	A	Y	Z	T-TAN/BROWN A-COARSE Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS	38	45
T	A	G		T-TAN/BROWN A-COARSE G-GRAVEL/STONES	45	62
T	W	Y		T-TAN/BROWN W-WATER BEARING Y-SAND & GRAVEL	62	72

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM53 SA-53B 4.5X237 PARAGON WELDED	Surface	69
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	STAINLESS 12 SLOT	69	72

7. Grout or Other Sealing Material

Method MOUNDED BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level
38 ft. below ground surface

10. Pump Test
Pumping level 65 ft. below surface
Pumping at 8 GP M for 10 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JR	6202	09-22-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		54

Comment:

Created On: 09-22-2025 Updated On: 10-27-2025 Review Status: APPROVED