

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACI207		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner KESSLER JESSIE						Phone # (715)520-7997		1. Well Location				Fire # (if avail.)		
Mailing Address N7415 CORRELL RD.						Town of SPRINGBROOK						N7415		
City TREGO						State WI		Zip Code 54888				Street Address or Road Name and Number N7415 CORRELL RD.		
County Washburn		Co. Permit #		Notification # 9929321701		Completed 08-14-2025		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) RUTHERFORD, JEFFREY J				Lic. # 6202		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.9039 °N -91.7644 °W				Method Code OTH001		
Address H2O WELL & PUMP N11455 MC CLAIN LAKE RD TREGO WI 54888				Well Plan Approval #		NE SE		Section 31		Township 40 N		Range 11 W		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled								
3. Well serves 1 # of HOME				Hicap Well ? No										
Private, potable				Hicap Property ? No										
Heat Exchange ___ # of drillholes				Hicap Potable ? No										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
4		Surface		72		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>Yes</u> Cable-tool Bit 3.75in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
T A Y				T-TAN/BROWN A-COARSE Y-SAND & GRAVEL				Surface		38				
T A Y Z				T-TAN/BROWN A-COARSE Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS				38		45				
T A G				T-TAN/BROWN A-COARSE G-GRAVEL/STONES				45		62				
T W Y				T-TAN/BROWN W-WATER BEARING Y-SAND & GRAVEL				62		72				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
4		ASTM53 SA-53B 4.5X237 PARAGON WELDED				Surface		69						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
3		STAINLESS 12 SLOT				69		72						
7. Grout or Other Sealing Material														
Method MOUNDED BENTONITE														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GRANULAR BENTONITE				Surface										
9. Static Water Level														
38 ft. below ground surface														
10. Pump Test														
Pumping level 65 ft. below surface														
Pumping at 8 GP M for 10 Hrs.														
Pumping Method ? Test Pump														
11. Well Is														
18 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? No														
Filled & Sealed Well(s) as needed? No														
13. Constructor / Supervisory Driller				Lic #		Date Signed								
JR				6202		09-22-2025								
Drill Rig Operator				Lic or Reg #		Date Signed								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		54

Comment:

Created On: 09-22-2025

Updated On: 10-27-2025

Review Status: APPROVED