Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACI210

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: FAIRBANKS, TIM	Phone #: (715)466-2630
Mailing Address: N11381 BURIAN PLACE RD.	
City: TREGO	State: WI — Zip Code: 54888
County: Washburn	Co. Permit #: WI — Notification #: 9929321702 — Completed: 08-26-2025
Well Constructor (Business Name): RUTHERFORD, JEFFREY J	Lic. #: 6202 — Facility ID # (Public Wells):
Address: H20 WELL & PUMP N11455 MC CLAIN LAKE RD, TREGO WI 54888	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.3

1. Well Location

Town of CHICOG	Fire # (if avail.): N11381
Street Address or Road Name and Number: N11381 BURIAN PLACE RD.	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.0439 °N -92.0084 °W	Method Code: OTH001
SE SE or Govt Lot #:	Section: 8 — Township: 41 N — Range: 13 W

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	108

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 3.75in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T M S	T-TAN/BROWN M-MEDIUM S-SAND	Surface	108

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM53 SA-53B 4.5X237 PARAGON WELDED	Surface	108
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
3	STAINLESS 10 SLOT	105	108

7. Grout or Other Sealing Material

Method MOUNDED BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level
87 ft. below ground surface

10. Pump Test
Pumping level 95 ft. below surface
Pumping at 10 GP M for 20 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JR	6202	09-22-2025
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
		09-22-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		65

Comment:

Created On: 09-22-2025 Updated On: 10-27-2025 Review Status: APPROVED