

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACI210		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner FAIRBANKS, TIM					Phone # (715)466-2630		1. Well Location				Fire # (if avail.)						
Mailing Address N11381 BURIAN PLACE RD.							Town of CHICO				N11381						
City TREGO					State WI Zip Code 54888		Street Address or Road Name and Number N11381 BURIAN PLACE RD.										
County Washburn		Co. Permit # WI		Notification # 9929321702		Completed 08-26-2025		Subdivision Name			Lot # Block #						
Well Constructor (Business Name) RUTHERFORD, JEFFREY J				Lic. # 6202		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.0439 °N -92.0084 °W			Method Code OTH001						
Address H2O WELL & PUMP N11455 MC CLAIN LAKE RD TREGO WI 54888				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 8 41 N 13 W		2. Well Type New Well									
Hicap Permanent Well #				Common Well #		Specific Capacity 1.3		of previous unique well # constructed in					Reason for replaced or reconstructed well ?				
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable		Hicap Property ? No		Heat Exchange ___ # of drillholes			Hicap Potable ? No				
								Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
4		Surface		108		No Rotary - Mud Circulation		No		T M S		T-TAN/BROWN M-MEDIUM S-SAND		Surface		108	
						No Rotary - Air		No									
						No Rotary - Air & Foam		No									
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						Yes Cable-tool Bit 3.75in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		87 ft. below ground surface		18 in. above grade					
4		ASTM53 SA-53B 4.5X237 PARAGON WELDED				Surface		108		10. Pump Test		Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 95 ft. below surface		Disinfected ? Yes					
3		STAINLESS 10 SLOT				105		108		Pumping at 10 GP M for 20 Hrs.		Capped ? Yes					
7. Grout or Other Sealing Material												Pumping Method ? Test Pump					
Method MOUNDED BENTONITE												12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
GRANULAR BENTONITE				Surface													
13. Constructor / Supervisory Driller												Lic #		Date Signed			
JR												6202		09-22-2025			
Drill Rig Operator												Lic or Reg #		Date Signed			
														09-22-2025			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		65

Comment:

Created On: 09-22-2025

Updated On: 10-27-2025

Review Status: APPROVED