Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACI329

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ST CROIX, ED			Phone #
Mailing Address: 8932 92ND ST S			
City: COTTAGE GROVE	State: MN	Zip Code: 55016	
County: Barron	Co. Permit #	Notification #	Completed: 09-15-2025

Well Constructor (Business Name): DAHL WELL DRILLING LLC	Lic. #: 6724	Facility ID # (Public Wells)	
Address: 1236 HAGAN RD GLENWOOD CITY WI 54013		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 4	

1. Well Location

Town of ALMENA

Fire # (if avail.): 1215A

Street Address or Road Name and Number: 3 3/4 4TH ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 45.383 °N -92.074 °W

Method Code: GPS008

SE SE or Govt Lot #	Section: 34	Township: 34 N	Range: 14 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of CABIN

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	120

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	I		T-TAN/BROWN S-SOFT/LOOSE I-SOIL-ORGANIC	Surface	1
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	1	23
Y	Q	S		Y-YELLOW Q-CAVING S-SAND	23	63
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	63	106
E	H	N		E-GREEN H-HARD/FIRM N-SANDSTONE	106	118
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	118	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHRATLAND, ASTM A53, STEEL, WELDED, 20#/FT, 2.80 WALL	Surface	106
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 29 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	106	9 S

12. Notified Owner of need to fill & seal ? Yes

NA

Filled & Sealed Well(s) as needed? Yes

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
AD	6830	09-24-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		116

Comment: WELL PERMIT # 10004705801
COUNTY NEEDS TO BE CHANGED TO BARRON
PLEASE AND THANK YOU

Created On: 09-24-2025 Updated On: 10-28-2025 Review Status: APPROVED