Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACI548

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MEYER GARY	Phone #
Mailing Address: 375 NORTH HUMBOLT ST	
City: BUFFALO CITY	State: WI — Zip Code: 54622
County: Buffalo	Co. Permit #: — Notification #: 10019539801 — Completed: 09-30-2025

1. Well Location

City of BUFFALO CITY — Fire # (if avail.): 375

Street Address or Road Name and Number: 375 NORTH HUMBOLT ST

Subdivision Name: — Lot #: — Block #:

Well Constructor (Business Name): HARTERT, EDWARD A	Lic. #: 4424	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 44.23322 °N -91.86061 °W — Method Code: SCR002
Address: HARTERT WELL DRILLING 14497 N CTY RD 24 WABASHA MN 55981		Well Plan Approval #:	SW SE — Section: 6 — Township: 20 N — Range: 12 W — or Govt Lot #
		Approval Date (mm-dd-yyyy):	**2. Well Type** Replacement — of previous unique well # — constructed in
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 15	Reason for replaced or reconstructed well ?: SAND POINT FAILING
3. Well serves 1 # of HOME — Private,potable — Heat Exchange____# of drillholes		Hicap Well ? No — Hicap Property ? No — Hicap Potable ? No	Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	3
4	3	45

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	S	T-TAN/BROWN Q-CAVING S-SAND S-SANDY	Surface	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	STEEL,11.OOLBS' ASTMA53B. WEATLAND T-N-C	Surface	41
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	TELESCOPING SS 12SLOT	41	45

7. Grout or Other Sealing Material

Method: MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	41	1.5 S

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 14 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EH	4424	09-30-2025
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
EH	4424	09-30-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		82	Sewer - Building Sanitary		30
Building Drain - Sanitary		26	Septic or Holding, or POWTS Tank		48

Comment:

Created On: 09-30-2025 Updated On: 10-15-2026 Review Status: APPROVED