

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACI548		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner MEYER GARY				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 375 NORTH HUMBOLT ST				City BUFFALO CITY		City of BUFFALO CITY				375	
State WI				Zip Code 54622		Street Address or Road Name and Number 375 NORTH HUMBOLT ST					
County Buffalo		Co. Permit #		Notification # 10019539801		Completed 09-30-2025		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) HARTERT, EDWARD A				Lic. # 4424		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.23322 °N -91.86061 °W		Method Code SCR002	
Address HARTERT WELL DRILLING 14497 N CTY RD 24 WABASHA MN 55981				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 6 20 N 12 W		2. Well Type Replacement			
Hicap Permanent Well #				Common Well #		Specific Capacity 0		of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?		SAND POINT FAILING			
Private, potable				Hicap Property ? No		SAND POINT FAILING		Construction Type Drilled			
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes	
8		Surface		3		No Rotary - Mud Circulation		No		T Q S S	
4		3		45		No Rotary - Air		No		T-TAN/BROWN Q-CAVING S-SAND S-SANDY	
						No Rotary - Air & Foam		No			
						No Drill-Through Casing Hammer					
						No Reverse Rotary					
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Type, Caving/Noncaving, Color, Hardness, etc...											
From (ft.) To (ft.)											
Surface 45											
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level	
4		STEEL, 11.00 LBS' ASTMA53B. WEATLAND T-N-C				Surface		41		13 ft. below ground surface	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is	
4		TELESCOPING SS 12SLOT				41		45		18 in. above grade	
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test			
GRANULAR BENTONITE		Surface		41		1.5 S		Developed ? Yes			
Filled & Sealed Well(s) as needed? Yes											
12. Notified Owner of need to fill & seal ? Yes											
13. Constructor / Supervisory Driller											
EH		4424		09-30-2025		11. Well Is		Disinfected ? Yes			
Drill Rig Operator		Lic or Reg #		Date Signed		Capped ? Yes					
EH		4424		09-30-2025							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		82	Sewer - Building Sanitary		30
Building Drain - Sanitary		26	Septic or Holding, or POWTS Tank		48

Comment:

Created On: 09-30-2025

Updated On: 10-24-2025

Review Status: APPROVED