Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACI560

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MEYER ANDY & TINA	Phone #
Mailing Address: 177 HIGHLAND POINT DR	
City: ALTO	State: GA — Zip Code: 30510
County: Waushara	Co. Permit #: — Notification #: 9987289301 — Completed: 09-30-2025
Well Constructor (Business Name): VETTER, WILLIAM	Lic. #: 6351 — Facility ID # (Public Wells):
Address: 1036 TOWNSEND RD WAUPACA WI 54981	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 4.5

1. Well Location

Town of SAXEVILLE	Fire # (if avail.): W2899
Street Address or Road Name and Number: ALP DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.21957 °N -89.02609 °W	Method Code: SCR002
NW SW or Govt Lot #:	Section: 12 — Township: 20 N — Range: 12 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	160

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	X		T-TAN/BROWN S-SOFT/LOOSE X-SAND & CLAY	Surface	32
T	S	C		T-TAN/BROWN S-SOFT/LOOSE C-CLAY	32	53
T	H	Z		T-TAN/BROWN H-HARD/FIRM Z-CLAY & GRAVEL	53	60
T	S	C		T-TAN/BROWN S-SOFT/LOOSE C-CLAY	60	68
T	H	C		T-TAN/BROWN H-HARD/FIRM C-CLAY	68	141
T	S	Z		T-TAN/BROWN S-SOFT/LOOSE Z-CLAY & GRAVEL	141	151
T	W	Y		T-TAN/BROWN W-WATER BEARING Y-SAND & GRAVEL	151	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL WELDED JOINT WHEATLAND 18.97PDS PER FT 6.625X280A53GRB	Surface	156
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	SS.12 SLOT JOHNSON	156	160

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	20	6 S

9. Static Water Level	11. Well Is
9 ft. below ground surface	18 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 11 ft. below surface	Disinfected ? Yes
Pumping at 9 GP M for 3 Hrs.	Capped ? Yes
Pumping Method ? Test Pump	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WV	6351	10-01-2025
Drill Rig Operator	Lic or Reg #	Date Signed
GV	8784	10-01-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		60	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 10-01-2025 Updated On: 11-05-2025 Review Status: APPROVED