

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACI749		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ROSENTHAL, RON						Phone # (651)764-3338		1. Well Location				Fire # (if avail.)	
Mailing Address 27950 BAYVIEW DRIVE						Town of GEORGETOWN						2381	
City REDWING						State MN		Zip Code 55066				Street Address or Road Name and Number	
108TH ST						Subdivision Name				Lot #		Block #	
County Polk		Co. Permit #		Notification # 10019146801		Completed 11-07-2025		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) BEECROFT, BRANT C				Lic. # 7298		Facility ID # (Public Wells)				45.5516 °N -92.3821 °W		SCR002	
Address DANWELL COMPANY LLC 181 305TH AVE FREDERIC WI 54837				Well Plan Approval #		NW NW		Section 5		Township 35 N		Range 16 W	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 3		2. Well Type Replacement				of previous unique well # constructed in			
Reason for replaced or reconstructed well ?				WELL TOO CLOSE TO NEW HOUSE BUILD									
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled					
Private, potable						Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
5		Surface		270		No Rotary - Mud Circulation				No			
						No Rotary - Air				No			
						No Rotary - Air & Foam				No			
						No Drill-Through Casing Hammer							
						No Reverse Rotary							
						No Cable-tool Bit ___ in. dia...				No			
						No Dual Rotary				Yes			
						Yes Temp. Outer Casing 8in. dia							
						Yes Removed? 12depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)			
Y		Y-SAND & GRAVEL						Surface		12			
Z S		Z-CLAY & GRAVEL S-SANDY						12		33			
C Z		C-CLAY Z-W/COBBLES/BOULDERS						33		70			
Y Z		Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS						70		85			
S N		S-SOFT/LOOSE N-SANDSTONE						85		236			
H N		H-HARD/FIRM N-SANDSTONE						236		270			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
5		MURIUCHI ASTM A53B PLN END BT WLD				Surface		240					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE				Surface		240		15 S					
9. Static Water Level													
10 ft. below ground surface													
10. Pump Test													
Pumping level 20 ft. below surface													
Pumping at 30 GP M for 1 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? Yes													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
BCB				7298				12-30-2025					
Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	100	POWTS treatment component (septic tanks, aerobic treatment units or filters)		37
			POWTS dispersal component (soil absorption unit or mound)		75

Comment:

I CALLED JOHN BOWEN WHILE ONSITE TO CONTINUE INTO THE BEDROCK WITH 5" CASING. JOHN GAVE ME PERMISSION TO DO SO.

Created On: 10-06-2025**Updated On:** 01-05-2026**Review Status:** APPROVED