Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACI772

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NO LIMITS CONSTRUCTION			Phone #
Mailing Address: 81 161ST STREET			
City: AMERY	State: WI	Zip Code: 54001	
County: Polk	Co. Permit #	Notification #	Completed: 04-22-2026

1. Well Location

Fire # (if avail.)

Town of LINCOLN

Street Address or Road Name and Number: 759 115TH STREET

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
MCCULLOUGH AND SONS	44	

Latitude / Longitude in Decimal Degree (DD): 45.31615 °N -92.406 °W

Method Code: SCR002

Well Plan Approval #

NW SW or Govt Lot #	Section	Township	Range
	30	33 N	16 W

Address: 20335 FOREST BOULEVARD NORTH
FOREST LAKE MN 55025-9764

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.4

Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	82

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	I	S-SAND I-W/SOIL-ORGANIC	Surface	5
		Y		Y-SAND & GRAVEL	5	82

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NORTH AMERICAN PLASTIC SDR 21 F-480	Surface	78
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	JOHNSON STAINLESS 15 SLOT 6'	78	82

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 22 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
HIGH SOLIDS BENTONITE	Surface	72	6 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DM	72	04-24-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DM	7343	04-24-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		52	Sewer - Building Sanitary		130

Comment:

Created On: 10-06-2025 Updated On: 05-20-2026 Review Status: APPROVED