

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACI779		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner WHEELER DAVID					Phone #		1. Well Location				Fire # (if avail.)												
Mailing Address PO BOX 307					Village of LOHRVILLE					Street Address or Road Name and Number NORTH 4TH AVE													
City OMRO			State WI		Zip Code 54963																		
County Waushara		Co. Permit #		Notification # 10019263001		Completed 10-03-2025		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) VETTER, WILLIAM				Lic. # 6351		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.04135 °N -89.12648 °W			Method Code SCR002										
Address 1036 TOWNSEND RD WAUPACA WI 54981				Well Plan Approval #				SW SW Section Township Range or Govt Lot # 7 18 N 12 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
				Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #			Common Well #		Specific Capacity 1.8				3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes														
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No																			
				Hicap Property ? No																			
Hicap Potable ? No				Hicap Potable ? No				4. Potential Contamination Sources - ON REVERSE SIDE															
				Hicap Potable ? No																			
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
6		Surface		45		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary Yes Cable-tool Bit 6in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				T Q S		T-TAN/BROWN Q-CAVING S-SAND		Surface		6							
T		W		S		T-TAN/BROWN W-WATER BEARING S-SAND				6		45											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		6 ft. above ground surface				18 in. above grade									
6		STEEL WELDED JOINT WHEATLAND 18.97PDS PER FT 6.625X280A53GRB				Surface		42		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 11 ft. below surface Pumping at 9 GP M for 2 Hrs. Pumping Method ? Test Pump				Filled & Sealed Well(s) as needed? No									
6		SS. 10 SLOT JOHNSON				42		45															
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No				Filled & Sealed Well(s) as needed? No							
Method MOUNDED																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				13. Constructor / Supervisory Driller				Lic #		Date Signed					
GRANULAR BENTONITE				Surface		6		2 S								WV		6351		10-06-2025			
Drill Rig Operator												Lic or Reg #		Date Signed		GV				8784		10-06-2025	
												GV		8784						10-06-2025			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		40	POWTS dispersal component (soil absorption unit or mound)		60

Comment: PARCEL# 146007332700

Created On: 10-06-2025

Updated On: 11-07-2025

Review Status: APPROVED