Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACI842

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: THUROW AARON	Phone #
Mailing Address: N15619 SHRIRE LN.	
City: TREMPEALEAU	State: WI Zip Code: 54661

County	Co. Permit #	Notification #	Completed
Trempealeau	20240905	9953008901	07-30-2025

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LYSAKER, TIMOTHY M	6199	

Address: TIM LYSAKER WELL DRLG & PUMP SERV LLC N7912 BLUFFVIEW CT HOLMEN WI 54636

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.5

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of TREMPEALEAU

Fire # (if avail.) N15619

Street Address or Road Name and Number: N15619 SHIRE LN.

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.06492 °N -91.50347 °W	SCR002

SE NW or Govt Lot #	Section	Township	Range
	6	18 N	9 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	124

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	124

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK P.E. STEEL 10.79# .237 WALL ASTM A53B WHEATLAND	Surface	120
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	12 CONT SLOT STAINLESS STEEL JOHNSON	120	124

9. Static Water Level
85 ft. below ground surface

10. Pump Test
Pumping level 95 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	120	3 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TL	6199	07-30-2025
Drill Rig Operator	Lic or Reg #	Date Signed
TL		07-30-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		75	POWTS dispersal component (soil absorption unit or mound)		100
			Building Drain - Sanitary		25

Comment:

Created On: 10-08-2025 Updated On: 11-10-2025 Review Status: APPROVED