Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACI939

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: DELIVS WENDY	Phone #: (608)547-0582
Mailing Address: 381 EMBER CT	
City: OXFORD	State: WI — Zip Code: 53952
County: Adams	Co. Permit #:
Notification #: 10003467502	Completed: 03-18-2026
Well Constructor (Business Name): REICHHOFF, RODNEY J	Lic. #: 7202
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: W8740 EVERGREEN DR OXFORD WI 53952	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.6	

1. Well Location

Town of NEW CHESTER	Fire # (if avail.): 381
Street Address or Road Name and Number: EMBER CT	
Subdivision Name:	Lot #: 100 — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.8454 °N -89.6519 °W	Method Code: GPS008

NE	NW	Section	Township	Range
or Govt Lot #		27	16 N	7 E

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: NONREPAIRABLE

Construction Type: Jetted

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	64
1.25	64	67

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 1.25in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	15
		X		X-SAND & CLAY	15	50
		Y		Y-SAND & GRAVEL	50	67

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND ERW ASTM A 53 3.75# COUPLED	Surface	64
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	80 GA STAINLESS STEEL 3' POINT	64	67

9. Static Water Level

27 ft. below ground surface

10. Pump Test

Pumping level 43 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? No

Disinfected ? No

Capped ? No

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	43	1.5 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR	7202	03-23-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		41	POWTS dispersal component (soil absorption unit or mound)		52

Comment:

Created On: 10-09-2025 Updated On: 04-13-2026 Review Status: APPROVED