Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACJ128

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROTHE, RICK AND MELISSA	Phone #
Mailing Address: 14030 KNOWLS CREEK	
City: LAKEWOOD	State: WI — Zip Code: 54138
County: Oconto	Co. Permit #: — Notification #: 10030930101 — Completed: 12-17-2025
Well Constructor (Business Name): T & T WELL DRILLING & PUMP SERVICE	Lic. #: 6571 — Facility ID # (Public Wells):
Address: PO BOX 22, LAKEWOOD WI 54138	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #:	Specific Capacity: 0.2

1. Well Location

Town of LAKEWOOD	Fire # (if avail.): 14030
Street Address or Road Name and Number: KNOWLES CREEK RD	
Subdivision Name: — Lot #: — Block #:	
Latitude / Longitude in Decimal Degree (DD): 45.35994 °N -88.45447 °W	Method Code: SCR002
NW NE or Govt Lot #: — Section: 11 — Township: 33 N — Range: 16 E	

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	77
6	77	221

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	Yes
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	Z	Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS	Surface	35
		X	Z	X-SAND & CLAY Z-W/COBBLES/BOULDERS	35	55
		Y	Z	Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS	55	74
		Q		Q-GRANITE	74	221

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A-53 GRADE B WHEATLAND WELDED 18.97	Surface	77
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
QUICK GROUT	Surface	77	4 S

9. Static Water Level
60 ft. below ground surface

10. Pump Test
Pumping level 186 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TM	6220	01-16-2026
Drill Rig Operator	Lic or Reg #	Date Signed
MB	8359	01-16-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: MARK BRESNYAN 8359 IS RENEWED, WATER SAMPLES WILL BE COMPLETED IN SPRING WHEN WATER IS TURNED ON

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	02/09/2026	

Created On: 10-15-2025 Updated On: 10-15-2026 Review Status: APPROVED