

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACJ128		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ROTH, RICK AND MELISSA						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 14030 KNOWLS CREEK								Town of LAKEWOOD				14030	
City LAKEWOOD						State WI		Zip Code 54138					
County Oconto		Co. Permit #		Notification # 10030930101		Completed 12-17-2025		Subdivision Name				Lot #	
												Block #	
Well Constructor (Business Name)				Lic. # 6571		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)			
T & T WELL DRILLING & PUMP SERVICE										45.35994 °N -88.45447 °W			
Address PO BOX 22 LAKEWOOD WI 54138						Well Plan Approval #				NW NE		Section Township	
						Approval Date (mm-dd-yyyy)				11 33 N		Range 16 E	
Hicap Permanent Well #		Common Well #		Specific Capacity 0						2. Well Type New Well			
										of previous unique well # constructed in			
										Reason for replaced or reconstructed well ?			
										Construction Type Drilled			
3. Well serves 1 # of HOME						Hicap Well ? No							
Private, potable						Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
8.75		Surface		77		Yes Rotary - Mud Circulation			Yes				
6		77		221		Yes Rotary - Air			Yes				
						No Rotary - Air & Foam			No				
						No Drill-Through Casing Hammer							
						No Reverse Rotary							
						No Cable-tool Bit ___ in. dia...			No				
						No Dual Rotary			No				
						No Temp. Outer Casing ___ in. dia							
						No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
Y Z				Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS				Surface		35			
X Z				X-SAND & CLAY Z-W/COBBLES/BOULDERS				35		55			
Y Z				Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS				55		74			
Q				Q-GRANITE				74		221			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		A-53 GRADE B WHEATLAND WELDED 18.97				Surface		77					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
QUICK GROUT				Surface		77		4 S					
9. Static Water Level													
60 ft. below ground surface													
10. Pump Test													
Pumping level 186 ft. below surface													
Pumping at 20 GP M for 2 Hrs.													
Pumping Method ? Test Pump													
11. Well Is													
18 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
TM				6220				01-16-2026					
Drill Rig Operator													
Lic or Reg #				Date Signed									
MB				8359				01-16-2026					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment: MARK BRESNYAN 8359 IS RENEWED, WATER SAMPLES WILL BE COMPLETED IN SPRING WHEN WATER IS TURNED ON

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	02/09/2026	

Created On: 10-15-2025

Updated On: 02-09-2026

Review Status: APPROVED