

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACJ520		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner WITT, BRIAN Phone # (218)391-9488						1. Well Location				Fire # (if avail.)	
Mailing Address 715 N 22ND ST						Town of SUPERIOR					
City SUPERIOR State WI Zip Code 54880						Street Address or Road Name and Number 2300 S BIRCH TRAIL					
County Douglas		Co. Permit #		Notification # 10035928401		Completed 12-01-2025		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) KENT, ROBERT W				Lic. # 6791		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.609 °N -92.1837 °W		Method Code SCR002	
Address KENT WELL DRILLING 749 SEBOE RD WRENSHALL MN 55797				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 25 48 N 15 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2							
3. Well serves 1 # of HOME Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) 6		From (ft.) Surface		To (ft.) 160		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
						No Rotary - Mud Circulation No No Rotary - Air Yes No Rotary - Air & Foam No No Drill-Through Casing Hammer Reverse Rotary No Cable-tool Bit ____ in. dia... No Yes Dual Rotary No No Temp. Outer Casing ____ in. dia No Removed? ____ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) C C-CLAY Surface 158 Y Y-SAND & GRAVEL 158 160	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level	
6		WEATLAND SCH 40 .280 18.97				Surface		158		58 ft. below ground surface	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is	
										20 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No	
GRANULAR BENTONITE				Surface		158				Filled & Sealed Well(s) as needed? No	
13. Constructor / Supervisory Driller Lic # Date Signed RK 6791 12-17-2025 Drill Rig Operator Lic or Reg # Date Signed RK 12-17-2025											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		55

Comment:

Created On: 10-27-2025

Updated On: 01-21-2026

Review Status: APPROVED