Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACJ520

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WITT, BRIAN			Phone #: (218)391-9488
Mailing Address: 715 N 22ND ST			
City: SUPERIOR	State: WI	Zip Code: 54880	
County: Douglas	Co. Permit #:	Notification #: 10035928401	Completed: 12-01-2025

1. Well Location

Town of SUPERIOR

Fire # (if avail.)

Street Address or Road Name and Number: 2300 S BIRCH TRAIL

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): KENT, ROBERT W	Lic. #: 6791	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 46.609 °N -92.1837 °W
		Well Plan Approval #	Method Code: SCR002
Address: KENT WELL DRILLING 749 SEBOE RD WRENSHALL MN 55797		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #:	Specific Capacity: 0.2	

NE	SE	Section	Township	Range
or Govt Lot #		25	48 N	15 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	160

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
Yes	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		C-CLAY	Surface	158
		Y		Y-SAND & GRAVEL	158	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WEATLAND SCH 40 .280 18.97	Surface	158
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

58 ft. below ground surface

10. Pump Test

Pumping level 120 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	158	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RK	6791	12-17-2025
Drill Rig Operator	Lic or Reg #	Date Signed
RK		12-17-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		55

Comment:

Created On: 10-27-2025 Updated On: 01-21-2026 Review Status: APPROVED