

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACJ529		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner GRAND GENEVA RESORT						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 7036 GRAND GENEVA WAY								Town of LYONS											
City LAKE GENEVA						State WI		Zip Code 53147											
County Walworth		Co. Permit #		Notification #		Completed 09-21-2022		Street Address or Road Name and Number 7036 GRAND GENEVA WAY											
Subdivision Name						Lot #		Block #											
Well Constructor (Business Name) MUNICIPAL WELL & PUMP/MIDWEST WELL				Lic. # 13		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.6114 °N -88.3872 °W									
Address 1212 STORBECK DR WAUPUN WI 53963				Well Plan Approval #		SE SE		Section 20		Township 2 N		Method Code SCR002							
				Approval Date (mm-dd-yyyy)		Range 18 E													
Hicap Permanent Well #				Common Well #		Specific Capacity 7				2. Well Type New Well									
										of previous unique well # constructed in									
										Reason for replaced or reconstructed well ?									
										Construction Type Drilled									
3. Well serves # of TEST WELL						Hicap Well ? No													
Private, non-potable						Hicap Property ? No													
Heat Exchange ___ # of drillholes						Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
12		Surface		80		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>Yes</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)						G N Y M		G-GRAY N-FINE Y-SAND & GRAVEL M-SILTY		Surface		15	
												M Y		M-MEDIUM Y-SAND & GRAVEL		15		35	
												M S		M-MEDIUM S-SAND		35		50	
												Y G		Y-SAND & GRAVEL G-W/GRAVEL/STONES		50		77	
												T L		T-TAN/BROWN L-LIMESTONE/DOLOMITE		77		80	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8 ft. below ground surface				24 in. above grade					
12		A53 GRADE B BLACK CARBON STEEL, 0.375" WALL, WELDED				Surface		61		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 28 ft. below surface Pumping at 140 GP M for 1 Hrs. Pumping Method ? Airlift									
12		SS 30 SLOT TELESCOPING WITH K-PACKER				61		80											
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No							
13. Constructor / Supervisory Driller								Lic #		Date Signed									
MR								7819		10-27-2025									
Drill Rig Operator								Lic or Reg #		Date Signed									
MR								7819		10-27-2025									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 10-27-2025

Updated On: 12-01-2025

Review Status: APPROVED