Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACJ537

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BUEHLER BEN			Phone #
Mailing Address: 1166 HWY 45			
City: EAGLE RIVER	State: WI	Zip Code: 54521	
County: Vilas	Co. Permit #:	Notification #: 10036125201	Completed: 10-23-2025

Well Constructor (Business Name): ZDROIK WELL DRILLING AND PUMP SERVICES, LLC	Lic. #: 9221	Facility ID # (Public Wells):
Address: 5900 ROBIN DR. EAGLE RIVER WI 54521		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2

1. Well Location

Town of LINCOLN					Fire # (if avail.): 1166
Street Address or Road Name and Number: HWY 45					
Subdivision Name: `			Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9094 °N -89.225 °W					Method Code: SCR002
SW NE or Govt Lot #:		Section: 34	Township: 40 N		Range: 10 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: LACK OF WATER

Construction Type: Drilled

3. Well serves 3 # of 1 OFFICE 2 HOMES

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	38

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	S-SAND	Surface	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6" 280 WALL 20' BLK PE	Surface	35
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	SS 10 SLOT	35	38

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	20	0.5 S

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JZ	7837	11-17-2025
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JZ	7837	11-17-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time		OWER WILL LET US KNOW WHEN HE IS READY FOR HOOKUP - NOT SURE IT WILL BE WITHIN THE SUBMISSION WINDOW

Created On: 10-27-2025 Updated On: 12-26-2025 Review Status: APPROVED