Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACJ538

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	VAN SKYHAWK, CHUCK
Phone #	
Mailing Address	5628 CLOVERLAND DR
City	EAGLE RIVER
State	WI
Zip Code	54521
County	Vilas
Co. Permit #	
Notification #	10037072001
Completed	10-24-2025
Well Constructor (Business Name)	ZDROIK WELL DRILLING AND PUMP SERVICES, LLC
Lic. #	9221
Facility ID # (Public Wells)	
Address	5900 ROBIN DR. EAGLE RIVER WI 54521
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	2.5

1. Well Location

Town of CLOVERLAND	Fire # (if avail.) 5628
Street Address or Road Name and Number	CLOVERLAND DR
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	45.902 °N -89.3155 °W
Method Code	SCR002
SE SW or Govt Lot #	
Section	36
Township	40 N
Range	9 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	38

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	Z	S-SAND Z-W/COBBLES/BOULDERS	Surface	20
		C		C-CLAY	20	30
		Y		Y-SAND & GRAVEL	30	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6" 280 WALL 20' BLK PE	Surface	35
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	SS 10 SLOT	35	38

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	10	0.5 S

9. Static Water Level

10 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 25 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JZ	7837	11-17-2025
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JZ	7837	11-17-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 10-27-2025 Updated On: 12-23-2025 Review Status: APPROVED