

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACJ538		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner VAN SKYHAWK, CHUCK						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address 5628 CLOVERLAND DR						Town of CLOVERLAND						5628											
City EAGLE RIVER						State WI		Zip Code 54521				Street Address or Road Name and Number CLOVERLAND DR											
County Vilas		Co. Permit #		Notification # 10037072001		Completed 10-24-2025		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) ZDROIK WELL DRILLING AND PUMP SERVICES, LLC				Lic. # 9221		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.902 °N -89.3155 °W			Method Code SCR002												
Address 5900 ROBIN DR. EAGLE RIVER WI 54521				Well Plan Approval #		SE SW		Section 36		Township 40 N		Range 9 E											
				Approval Date (mm-dd-yyyy)		or Govt Lot #																	
Hicap Permanent Well #		Common Well #		Specific Capacity 2.5		2. Well Type New Well																	
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled															
						Hicap Property ? No																	
						Hicap Potable ? No																	
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method																							
Dia. (in.) 6		From (ft.) Surface		To (ft.) 38		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
						No Rotary - Mud Circulation		No				S Z		S-SAND Z-W/COBBLES/BOULDERS		Surface		20					
						No Rotary - Air		No				C		C-CLAY		20		30					
						No Rotary - Air & Foam		No				Y		Y-SAND & GRAVEL		30		38					
						Yes Drill-Through Casing Hammer																	
						No Reverse Rotary																	
						No Cable-tool Bit ___ in. dia...		No															
						No Dual Rotary		No															
						No Temp. Outer Casing ___ in. dia																	
						No Removed? ___ depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.) 6		Material, Weight, Specification 6" 280 WALL 20' BLK PE				From (ft.) Surface		To (ft.) 35		10 ft. below ground surface				15 in. above grade									
Dia. (in.) 6		Screen type, material & slot size SS 10 SLOT				From (ft.) 35		To (ft.) 38		10. Pump Test				Developed ? Yes									
										Pumping level 20 ft. below surface				Disinfected ? Yes									
										Pumping at 25 GP M for 2 Hrs.				Capped ? Yes									
										Pumping Method ? Airlift													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No									
Method MOUNDED																							
Kind of Sealing Material GRANULAR BENTONITE		From (ft.) Surface		To (ft.) 10		# Sacks Cement 0.5 S						Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller								Lic #		Date Signed													
JZ								7837		11-17-2025													
Drill Rig Operator								Lic or Reg #		Date Signed													
JZ								7837		11-17-2025													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 10-27-2025

Updated On: 12-23-2025

Review Status: APPROVED