Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACJ603

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROEPKE THOMAS	Phone #
Mailing Address: 738 ISLE OF B	
City: EAGLE RIVER	State: WI — Zip Code: 54521
County: Vilas	Co. Permit #: — Notification #: 10036785701 — Completed: 10-24-2025
Well Constructor (Business Name): ZDROIK WELL DRILLING AND PUMP SERVICES, LLC	Lic. #: 9221 — Facility ID # (Public Wells): — Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Address: 5900 ROBIN DR. EAGLE RIVER WI 54521	
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 4	

1. Well Location

Town of LINCOLN				Fire # (if avail.): 738
Street Address or Road Name and Number: ISLE OF B				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 45.8895 °N -89.209 °W				Method Code: SCR002
SE SW or Govt Lot #:	Section: 2	Township: 39 N	Range: 10 E	

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	82

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	20
G		Y		G-GRAY Y-SAND & GRAVEL	20	70
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	70	75
		G		G-GRAVEL/STONES	75	82

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6" 280 WALL 20' BLK PE	Surface	79
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	OPEN HOLE	79	82

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	15	0.5 S

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 40 GP M for 2 Hrs.
Pumping Method ? Airlift

11. Well Is
36 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JZ	7837	10-30-2025
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JZ	7837	10-30-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 10-28-2025 Updated On: 12-07-2025 Review Status: APPROVED