

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACJ669		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner KRUEGER, BRAD					Phone #		1. Well Location Fire # (if avail.) Town of NORTH BEND N1573 Street Address or Road Name and Number WEST INDIES RD				Subdivision Name Lot # Block #	
Mailing Address N1573 WEST INDIES RD												
City MELROSE			State WI		Zip Code 54642		Latitude / Longitude in Decimal Degree (DD) 44.12524 °N -91.08091 °W Method Code GPS008					
County Jackson		Co. Permit #		Notification # 10031134701		Completed 10-27-2025						
Well Constructor (Business Name) RUSH, JON A				Lic. # 5837		Facility ID # (Public Wells)		SW NE Section Township Range		or Govt Lot # 15 19 N 6 W		
Address RUSH WELL DRLG LLC N7570 ODEEN ROAD BLACK RIVER FALLS WI 54615				Well Plan Approval #		Approval Date (mm-dd-yyyy)		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? SHALLOW CASING DEPTH IN OLD WELL				
Hicap Permanent Well #			Common Well #		Specific Capacity 0		Construction Type Drilled					
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)			
10 Surface 35			No Rotary - Mud Circulation			No			T Q X T-TAN/BROWN Q-CAVING X-SAND & CLAY Surface 16			
6 35 75			No Rotary - Air			No			T S X T-TAN/BROWN S-SOFT/LOOSE X-SAND & CLAY 16 36			
			No Rotary - Air & Foam			No			G H N G-GRAY H-HARD/FIRM N-SANDSTONE 36 75			
			No Drill-Through Casing Hammer									
			No Reverse Rotary									
			Yes Cable-tool Bit 10in. dia...			No						
			No Dual Rotary			No						
			Yes Temp. Outer Casing 10in. dia									
			Yes Removed? 17depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 32 ft. below ground surface		
6		STEEL / 18.97#FT/ASTMA53B/ LEAVITT/ WELDED				Surface		36		11. Well Is 18 in. above grade		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 38 ft. below surface Pumping at 10 GP M for 1 Hrs. Pumping Method ? Test Pump		
										Developed ? Yes Disinfected ? Yes Capped ? Yes		
7. Grout or Other Sealing Material												
Method TREMIE PIPE - PUMPED												
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Yes			
NEAT CEMENT GROUT			Surface		36		22 S		Filled & Sealed Well(s) as needed? Yes			
13. Constructor / Supervisory Driller Lic # Date Signed												
JAR 5837 10-29-2025												
Drill Rig Operator Lic or Reg # Date Signed												

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		75	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 10-29-2025

Updated On: 12-07-2025

Review Status: APPROVED