Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACJ669

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KRUEGER, BRAD			Phone #
Mailing Address: N1573 WEST INDIES RD			
City: MELROSE	State: WI	Zip Code: 54642	
County: Jackson	Co. Permit #:	Notification #: 10031134701	Completed: 10-27-2025

1. Well Location

Town of NORTH BEND

Fire # (if avail.): N1573

Street Address or Road Name and Number: WEST INDIES RD

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): RUSH, JON A	Lic. #: 5837	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 44.12524 °N -91.08091 °W
		Well Plan Approval #	Method Code: GPS008
Address: RUSH WELL DRLG LLC N7570 ODEEN ROAD, BLACK RIVER FALLS WI 54615		Approval Date (mm-dd-yyyy)	SW NE or Govt Lot #; Section: 15; Township: 19 N; Range: 6 W

2. Well Type Replacement

of previous unique well # | constructed in

Reason for replaced or reconstructed well ?: SHALLOW CASING DEPTH IN OLD WELL

Hicap Permanent Well #	Common Well #	Specific Capacity: 1.7

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	35
6	35	75

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 17depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	X		T-TAN/BROWN Q-CAVING X-SAND & CLAY	Surface	16
T	S	X		T-TAN/BROWN S-SOFT/LOOSE X-SAND & CLAY	16	36
G	H	N		G-GRAY H-HARD/FIRM N-SANDSTONE	36	75

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL / 18.97#FT/ASTMA53B/ LEAVITT/ WELDED	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

32 ft. below ground surface

10. Pump Test

Pumping level 38 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	36	22 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAR	5837	10-29-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		75	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 10-29-2025 Updated On: 10-15-2026 Review Status: APPROVED