

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACJ719		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner LARRABEE BEN						Phone #							
Mailing Address 3892 FUR FARM RD						Town of PLUM LAKE						Fire # (if avail.) 3892	
City CONOVER						State WI		Zip Code 54519				Street Address or Road Name and Number FUR FARM RD	
County Vilas		Co. Permit #		Notification # 10039543201		Completed 10-28-2025		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) ZDROIK WELL DRILLING AND PUMP SERVICES, LLC				Lic. # 9221		Facility ID # (Public Wells) Well Plan Approval # Approval Date (mm-dd-yyyy)				Latitude / Longitude in Decimal Degree (DD) 46.0346 °N -89.4063 °W Method Code GPS008			
Address 5900 ROBIN DR. EAGLE RIVER WI 54521				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 17 41 N 9 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
Hicap Permanent Well #		Common Well #		Specific Capacity 3		Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes													
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
6		Surface		30		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S		S-SAND				Surface		30					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		6" 280 WALL 20' BLK PE				Surface		27					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
6		SS 10 SLOT				27		30					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE				Surface		20		0.5 S					
9. Static Water Level													
15 ft. below ground surface													
10. Pump Test													
Pumping level 25 ft. below surface Pumping at 30 GP M for 2 Hrs. Pumping Method ? Airlift													
11. Well Is													
20 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
JZ				7837				10-30-2025					
Drill Rig Operator				Lic or Reg #				Date Signed					
JZ				7837				10-30-2025					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 10-30-2025

Updated On: 12-07-2025

Review Status: APPROVED