Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACJ741

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROEHRIG GARY			Phone #: (920)418-3612
Mailing Address: W2215 KEIL RD			
City: NEW HOLSTEIN	State: WI	Zip Code: 53061	
County: Marinette	Co. Permit #:	Notification #: 10019969701	Completed: 10-15-2025

1. Well Location

Fire # (if avail.): 10420

Town of AMBERG

Street Address or Road Name and Number: N10420 BENSON LK RD

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): DAMA PLBG & HTG INC	Lic. #: 6013	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 45.5069 °N -88.11388 °W
Address: 716 MAIN AVE, CRIVITZ WI 54114		Well Plan Approval #	Method Code: SCR002
		Approval Date (mm-dd-yyyy)	SW NW or Govt Lot #: Section: 15 Township: 35 N Range: 19 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NON- COMPLIANT

Construction Type: Driven Point

Hicap Permanent Well #	Common Well #	Specific Capacity: 0.4

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	28

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	ASTM A53 GALVANIZED	Surface	25
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	80 GAUZE GALVANIZED	25	28

7. Grout or Other Sealing Material

Method

8. Geology

9. Static Water Level

16 ft. below ground surface

10. Pump Test

Pumping level 28 ft. below surface

Pumping at 5 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

36 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MKD	3725	10-15-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Septic or Holding, or POWTS Tank		25

Comment:

Created On: 10-31-2025 Updated On: 10-15-2026 Review Status: APPROVED