

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACJ793		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BREOTZMANN, SHELLY						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 3025 E MILICHESKY RD						Town of SUMMIT													
City FOXBORO						State WI		Zip Code 54836											
County Douglas		Co. Permit #		Notification # 10034869701		Completed 11-27-2025		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) KENT, ROBERT W				Lic. # 6791		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.4772 °N -92.1435 °W				Method Code SCR002					
Address KENT WELL DRILLING 749 SEBOE RD WRENSHALL MN 55797				Well Plan Approval #		SW SE		Section 8		Township 46 N		Range 14 W							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		2. Well Type Replacement				of previous unique well # constructed in									
						Reason for replaced or reconstructed well ? LOW VOLUME													
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled													
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		93		No Rotary - Mud Circulation		No		S		S-SAND		Surface		15			
						No Rotary - Air		Yes		C M		C-CLAY M-SILTY		15		90			
						No Rotary - Air & Foam		No		G		G-GRAVEL/STONES		90		93			
						Yes Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		50 ft. below ground surface				20 in. above grade					
6		WEATLAND SCH 40 .280 18.97				Surface		93		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface				Disinfected ? Yes					
										Pumping at 15 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ? Airlift									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?				Yes			
Method MOUNDED												DIDNT WANT TO SEAL YET							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No					
GRANULAR BENTONITE				Surface		93				STILL PLANNING TO USE ???									
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												RK				6791		12-17-2025	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												RK						12-17-2025	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		70

Comment:

Created On: 11-03-2025

Updated On: 01-22-2026

Review Status: APPROVED