Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACJ793

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BREOTZMANN, SHELLY			Phone #
Mailing Address: 3025 E MILICHESKY RD			
City: FOXBORO	State: WI	Zip Code: 54836	
County: Douglas	Co. Permit #:	Notification #: 10034869701	Completed: 11-27-2025

Well Constructor (Business Name): KENT, ROBERT W	Lic. #: 6791	Facility ID # (Public Wells):	
Address: KENT WELL DRILLING 749 SEBOE RD WRENSHALL MN 55797		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

1. Well Location

Town of SUMMIT

Fire # (if avail.):

Street Address or Road Name and Number: 3025 E MILCHESKY RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 46.4772 °N -92.1435 °W	Method Code: SCR002			
SW SE or Govt Lot #:	Section: 8	Township: 46 N	Range: 14 W	

2. Well Type Replacement

of previous unique well #: constructed in: 1945

Reason for replaced or reconstructed well ?: LOW VOLUME

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	93

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	15
		C	M	C-CLAY M-SILTY	15	90
		G		G-GRAVEL/STONES	90	93

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WEATLAND SCH 40 .280 18.97	Surface	93
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	93	

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RK	6791	12-17-2025
Drill Rig Operator	Lic or Reg #	Date Signed
RK		12-17-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		70

Comment:

Created On: 11-03-2025 Updated On: 08-18-2026 Review Status: APPROVED