

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACJ864		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner GERK, MORGAN						Phone # (715)944-7667		1. Well Location				Fire # (if avail.)			
Mailing Address 89100 BARK POINT RD						Town of CLOVER						89100			
City HERBSTER						State WI		Zip Code 54844				Street Address or Road Name and Number 89100 BARK POINT RD			
County Bayfield		Co. Permit #		Notification # 10015603901		Completed 11-07-2025		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) MELIN, ROBERT T				Lic. # 111		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.86324 °N -91.21935 °W				Method Code GPS008	
Address MELIN WELL DRILLING 1318 MACARTHUR AVE ASHLAND WI 54806-3825				Well Plan Approval #		SE SE		Section 27		Township 51 N		Range 7 W			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2				2. Well Type New Well					
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ?					
Private, potable Drillhole				Hicap Potable ? No		Construction Type Drilled									
3. Well serves 1 # of HOME															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
10		Surface		289		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
S		S-SAND				Surface		5							
X		X-SAND & CLAY				5		15							
Y		Y-SAND & GRAVEL				15		20							
Y		Y-SAND & GRAVEL				20		75							
Y		Y-SAND & GRAVEL				75		95							
N S		N-FINE S-SAND				95		130							
A S		A-COARSE S-SAND				130		135							
P		P-HARDPAN				135		155							
N S		N-FINE S-SAND				155		195							
P		P-HARDPAN				195		265							
A S		A-COARSE S-SAND				265		290							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
5		PVC-SDR-17-250 PSI F-450 EAGLE				Surface		269							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
5		JOHNSON-PVC-20 SLOT				269		289							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE		Surface		155		90 S									

9. Static Water Level

112 ft. below ground surface

10. Pump Test

Pumping level 144 ft. below surface

Pumping at 5 GP M for 2 Hrs.

Pumping Method ? Other

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

RTM

111

12-01-2025

Drill Rig Operator

Lic or Reg #

Date Signed

JJP

9257

12-01-2025

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment: GEOLOGY: 5-15 INCLUDES BOULDERS
20-75 INCLUDES CLAY

Created On: 11-05-2025

Updated On: 02-04-2026

Review Status: APPROVED