

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACJ926		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner DOUG DOMBROWSKI						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address N1969 KELLER RD						Town of MOUNTAIN						16441									
City MARINETTE						State WI		Zip Code 54143				Street Address or Road Name and Number WINSLOW LAKE RD									
County Oconto		Co. Permit #		Notification # 10048913401		Completed 03-24-2026		Subdivision Name			Lot #		Block #								
Well Constructor (Business Name) T & T WELL DRILLING & PUMP SERVICE				Lic. # 6571		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.2729 °N -88.5215 °W			Method Code SCR002										
Address PO BOX 22 LAKEWOOD WI 54138				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 8 32 N 16 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
				Approval Date (mm-dd-yyyy)																	
Hicap Permanent Well #		Common Well #		Specific Capacity 0																	
3. Well serves 1 # of CABIN Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		90		Yes Rotary - Mud Circulation				No		Y Z		Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS		Surface		90			
6		90		100		Yes Rotary - Air				No		Y		Y-SAND & GRAVEL		90		100			
						No Rotary - Air & Foam				No											
						No Drill-Through Casing Hammer															
						No Reverse Rotary															
						No Cable-tool Bit ___ in. dia...				No											
						No Dual Rotary				No											
						No Temp. Outer Casing ___ in. dia															
						No Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		60 ft. below ground surface				24 in. above grade							
6		A-53 GRADE B WHEATLAND WELDED 18.97				Surface		96		10. Pump Test Pumping level 86 ft. below surface Pumping at 18 GP M for 2 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
5		12# SLOT SS				96		100													
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED														12. Notified Owner of need to fill & seal ? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No											
QUICK GROUT				Surface		90		14 S													
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														TM				6220		03-26-2026	
														Drill Rig Operator				Lic or Reg #		Date Signed	
														MB				8359		03-26-2026	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		75	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 11-06-2025

Updated On: 04-21-2026

Review Status: APPROVED