

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACJ985		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner POLSON, JEFF AND CHRISTINE						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 5212 S DARROW RD						Town of SUPERIOR													
City SUPERIOR						State WI		Zip Code 54880				Street Address or Road Name and Number 4374 E TWIN CREEK RD							
County Douglas		Co. Permit #		Notification # 9949277204		Completed 11-07-2025		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) KENT, ROBERT W				Lic. # 6791		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.5754 °N -92.0854 °W									
				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 11 47 N 14 W													
Address KENT WELL DRILLING 749 SEBOE RD WRENSHALL MN 55797				Approval Date (mm-dd-yyyy)		2. Well Type New Well													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2				Reason for replaced or reconstructed well ?									
3. Well serves 1 # of HOME				Hicap Well ? No															
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		202		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>Yes</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)						C		C-CLAY		Surface		123	
												N		N-SANDSTONE		123		202	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		80 ft. below ground surface				20 in. above grade					
6		WEATLAND SCH 40 .280 18.97				Surface		124		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 180 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ? Airlift									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No							
Method MOUNDED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No									
GRANULAR BENTONITE				Surface		124													
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												RK				6791		12-17-2025	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												RK						12-17-2025	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 11-10-2025

Updated On: 01-22-2026

Review Status: APPROVED