

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK088		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner PINNOW, BRIAN						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N7303 HIDDEN PRAIRIE RD								Town of HOLLAND				N7303			
City HOLMEN						State WI		Zip Code 54636				Street Address or Road Name and Number N7303 HIDDEN PRAIRIE RD			
County La Crosse		Co. Permit # 2024084		Notification # 9986501901		Completed 09-05-2025		Subdivision Name HIDDEN PRAIRIE				Lot # 2 Block #			
Well Constructor (Business Name) LYSAKER, DAVID LLOYD				Lic. # 8130		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9843 °N -91.3115 °W				Method Code SCR002	
Address 11982 SOUTH ST TREMPPEALEAU WI 54661				Well Plan Approval #		NE NE		Section 3		Township 17 N		Range 8 W			
Approval Date (mm-dd-yyyy)				or Govt Lot #		2. Well Type New Well									
Hicap Permanent Well #				Common Well #		Specific Capacity 0.5				of previous unique well #				constructed in	
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?									
Private, potable				Hicap Property ? No		Construction Type Drilled									
Heat Exchange ___ # of drillholes				Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
4		Surface		127		No Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)				To (ft.)			
T Y				T-TAN/BROWN Y-SAND & GRAVEL				Surface				127			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is	
4		NEW P.E. BLACK STEEL, .237WALL, 10.79#, ASTM A53B, WHEATLAND, WELDED				Surface		124		85 ft. below ground surface				14 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes	
3.5		.15SLOT CONT. STAINLESS STEEL				124		127		Pumping level 115 ft. below surface				Disinfected ? Yes	
										Pumping at 15 GP M for 24 Hrs.				Capped ? Yes	
										Pumping Method ? Test Pump					
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No					
GRANULAR BENTONITE				Surface		124		2 S		Filled & Sealed Well(s) as needed? No					
13. Constructor / Supervisory Driller															
DL				Lic # 8130		Date Signed 09-05-2025									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		28	Building Drain - Sanitary		10
POWTS dispersal component (soil absorption unit or mound)		70	Sewer - Building Sanitary		12

Comment:

Created On: 11-12-2025

Updated On: 12-22-2025

Review Status: APPROVED