Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK088

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PINNOW, BRIAN	Phone #
Mailing Address: N7303 HIDDEN PRAIRIE RD	
City: HOLMEN	State: WI — Zip Code: 54636

County	Co. Permit #	Notification #	Completed
La Crosse	2024084	9986501901	09-05-2025

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LYSAKER, DAVID LLOYD	8130	

Address: 11982 SOUTH ST, TREMPEALEAU WI 54661

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.5

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of HOLLAND

Fire # (if avail.): N7303

Street Address or Road Name and Number: N7303 HIDDEN PRAIRIE RD

Subdivision Name	Lot #	Block #
HIDDEN PRAIRIE	2	

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.9843 °N -91.3115 °W	SCR002

NE NE or Govt Lot #	Section	Township	Range
	3	17 N	8 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	127

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Y	T-TAN/BROWN Y-SAND & GRAVEL	Surface	127

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW P.E. BLACK STEEL, .237WALL, 10.79#, ASTM A53B, WHEATLAND, WELDED	Surface	124
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	.15SLOT CONT. STAINLESS STEEL	124	127

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	124	2 S

9. Static Water Level
85 ft. below ground surface

10. Pump Test
Pumping level 115 ft. below surface
Pumping at 15 GP M for 24 Hrs.
Pumping Method ? Test Pump

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DL	8130	09-05-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		28
POWTS dispersal component (soil absorption unit or mound)		70

Type	Qualifier	Distance
Building Drain - Sanitary		10
Sewer - Building Sanitary		12

Comment:

Created On: 11-12-2025 Updated On: 12-22-2025 Review Status: APPROVED